

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 89421
 Permit No. _____
 Basin 90

NOTICE OF INTENT NO. _____

1. OWNER GLENBROOK HOMEOWNERS ASSN. ADDRESS AT WELL LOCATION GLENBROOK GOLF COURSE
 MAILING ADDRESS GLENBROOK, NV GLENBROOK, NV

2. LOCATION SE 1/4 SE 1/4 Sec 3 T. 14N N/S R 18 E DOUGLAS County

PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Medium Brown Silty Sand (SM), with Gravel		0	2	2
Light Brown Silty Sand (SM), Med. Dense		2	9	7
Ground Water (Unstabilized)		4'		
Grey Brown Clayey Sand (SC), Fine - Medium Grained		9	TD	3+

8. WELL CONSTRUCTION
 Depth Drilled 12 Feet Depth Cased 12 Feet

HOLE DIAMETER (BIT SIZE)
 From 0 Feet To 12 Feet
3" Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
1.5"	Sch 40	PVC	0	12

Perforations:
 Type perforation Saw Cut
 Size perforation 0.03"
 From 3 feet to 12 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 3' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 3 feet to 12 feet

9. WATER LEVEL
 Static water level _____ feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started December 23, 1999, 19_____
 Date completed December 28, 1999, 19_____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Soils Engineering of NEVADA
 Contractor
 Address 820 Kuenzi Sr
RENO, NV 89502
 Contractor
 Nevada contractor's license number issued by the State Contractor's Board N/A (P.E.)
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M 2045
 Signed Allen Eggle
 By driller performing actual drilling on site or contractor
 Date April 23, 2001