WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 89437
Permit No.
Basin 103

NOTICE OF INTENT NO. 48667

1. OWNER English Mountain Catholic Church
MAILING ADDRESS PO Box 309 Dayton, NV 89403
ADDRESS AT WELL LOCATION #3 Melanie Dr Dayton, NV 89403

2. LOCATION NE ¼ NW ¼ Sec. 5 T. 16 N/S R. 22 E/W Lyon County
PERMIT NO. 66849 Issued by Water Resources
Parcel No. 16-311-46
Subdivision Name

3. WORK PERFORMED
☐ New Well ☑ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
QM ☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
D.G. SAND		0	15	15
D.G. GRAVEL		15	45	30
BROWN CLAY		45	60	15
SAND + GRAVEL		60	100	40
GREY CLAY + SAND		100	120	20
GREY CLAY		120	129	9
GREY SAND + GRAVEL		129	160	31
BROWN SAND + GRAVEL		160	180	20

RECEIVED 03 APR 21 AM 11:57 STATE ENGINEERS OFFICE

Date started 3-6-03, 20
Date completed 3-13-03, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50		2

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
12¼	0	180

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝		.188	0	180

Perforations:
Type perforation FACTORY
Size perforation
From 160 feet to 180 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 180 feet to 50 feet

9. WATER LEVEL
Static water level 41 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Nevada Pump & Drilling (Contractor)
Address P.O. Box 2227 Dayton, NV 89403 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 046357
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2187
Signed Thomas Evans (By driller performing actual drilling on site or contractor)
Date 4-4-03

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627