

STATE OF NEVADA
 DEPARTMENT OF WATER RESOURCES
 WELL DRILLER'S REPORT

office use only
 Log No. **89453**
 Permit No. _____
 Basin **Ø89**



NOTICE OF INTENT NO 50170

1. OWNER **Robert Hedland**
 MAILING ADDRESS **3820 Doc Olena**
Reno NV

ADDRESS AT WELL LOCATION **3820 Doc Olena**

2. Location **SW 1/4 SW 1/4 S 25 T 16N R 20E** Washoe County
 PERMIT NO. _____ PARCEL NO. **050-301-37** SUBDIVISION NAME _____

3. WORK PERFORMED			PROPOSED USE			5. WELL TYPE		
<input checked="" type="checkbox"/> New Well	Replace	Recondition	<input type="checkbox"/> Domestic	Irrigation	Test	<input type="checkbox"/> Cable	<input checked="" type="checkbox"/> Rotary	RVC
Deepen	Abandon	Other	Municipal/Industrial	Monitor	Stock	Air	Other	<input checked="" type="checkbox"/> Mud

6. LITHOLOGIC LOG					8. WELL CONSTRUCTION				
Material	Water Strata	From	To	Thickness	Depth Drilled		Depth Cased		HOLE DIAMETER (BIT SIZE)
Sand.		0	27	27	10 5/8	inches	0	feet	150 feet
Clay.		27	35	8		inches		feet	feet
Course sand.		35	53	18		inches		feet	feet
Clay.		53	67	14	CASING SCHEDULE				
Fractured rock.		67	98	31	Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
Clay.		98	133	35	6 5/8	12.94	188	+1 1/2	150
Course sand.		133	150	17	Perforations::				
				0	Type Perforation	Factory			
				0	Size perforation	3/32 x 3"			
				0	From	70	feet to	90	feet
				0	From	130	feet to	150	feet
				0	From		feet to		feet
				0	From		feet to		feet
				0	From		feet to		feet
				0	Surface Seal	<input checked="" type="checkbox"/> YES	No	Seal Type:	
				0	Depth of Seal	50	feet	Neat Cement	
				0				Pumped Cement Grout	
				0				Poured Concrete Grout	
				0	Gravel Packed:	Yes	No		
				0	From	50	feet to	150	feet
				0	9 WATER LEVEL				
				0	Static water level	40	feet below land surface		
				0	Artesian flow	0	GPM	0	P.S.I.
				0	Water Temperature	cold	Degrees F	Quality	

RECEIVED
 03 MAY -1 AM 10:58
 STATE ENGINEERS OFFICE

Date started **4-14 -03**
 Date completed **4-16 -03**

7. WELL TEST DATA			
TEST METHOD:	Bailer	Pump	x Air Lift
G.P.M.	Draw Down (Feet Below Static)		Time (hours)
30	20		
80	40		
100	60		
200	110		

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **McKay Drilling, Inc.**
2290 Pioneer Drive
Reno, NV 89509
 NV Contractors No. **14170**
 NV Driller's Lic (on site) **2121**
 Signed *Steve McKay*
 By driller performing actual drilling on site or contractor
 Date **4-17 -03**