

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15022

1. OWNER SAMUEL SALAZAR ADDRESS AT WELL LOCATION None
MAILING ADDRESS 698 Last Chance Rd #8
ELKO, NV 89801

2. LOCATION NW 1/4 NE 1/4 Sec 6 T 34 Q/S R 56 E ELKO County _____
PERMIT NO. N/A Issued by Water Resources _____ Parcel No. _____ Subdivision Name Bull, Last Chance Ranch

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil		0	1	1
Clay		1	89	89
Blue clay		89	271	182
Sandy clay	<u>SPRY</u>	271	272	1
Soft gray shale		272	293	21
Sandy clay	<u>29PR</u>	293	294	1
Soft gray sh		293	300	
Soft gray sh.		293	300	7
Soft blk ss	<u>159PR</u>	300	329	9
Blue shale		329	332	2

T.D. 332

8. WELL CONSTRUCTION
Depth Drilled 332 Feet Depth Cased 333 Feet

HOLE DIAMETER (BIT SIZE)
From To
10 Inches 0 Feet 54 Feet
8 Inches 54 Feet 332 Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>12.92</u>	<u>.188</u>	<u>+1</u>	<u>332</u>

Perforations:
Type perforation Torch cut
Size perforation 1/8 x 1" x 2 1/2"
From _____ feet to _____ feet
From 293 feet to 328 feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 30 ft Neat Cement
Placement Method: Pumped Poured Concrete Grout
Gravel Packed: Yes No
From 52 feet to T.D. (332) feet

Date started 3-10-03, 19____
Date completed 3-31-03, 19____

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>15</u>	<u>80</u>	<u>2 hrs</u>

9. WATER LEVEL
Static water level 148 feet below land surface
Artesian flow NO G.P.M. _____ P.S.I. _____
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name MUTH DRILLING CO Contractor
Address 203 PINE ST Contractor
ELKO, NV 89801
Nevada contractor's license number issued by the State Contractor's Board 10819
Nevada driller's license number issued by the Division of Water Resources, the on site driller 632
Signed James S. Muth
By driller performing actual drilling on site or contractor
Date 4-28-03