WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 894466
Permit No.
Basin 076

NOTICE OF INTENT NO. 48752

1. OWNER CHRH
MAILING ADDRESS P.O. Box 5010
Fallon,, NV 89407

ADDRESS AT WELL LOCATION 3560 Sweetwater Court,
Fernley, NV 89408

2. LOCATION SE 1/4 NE 1/4 Sec. 27 T 20N N/S R 25E E Lyon County
PERMIT NO. (Issued by Water Resources) Parcel No. 21-481-34 Subdivision Name

3. **WORK PERFORMED**
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. **PROPOSED USE**
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. **WELL TYPE**
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
Gravel w/Clay		0		
Stringers			200	200
Gravel		200	260	60
Gravel	XX	260	300	40

RECEIVED
03 APR 18 AM 10:50
STATE ENGINEER'S OFFICE

Date started 03/06/2003 , 19__
Date completed 03/06/2003 , 19__

7. **WELL TEST DATA**
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10		2hr

8. **WELL CONSTRUCTION**
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	300 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	20
6 PVC	3.92	.258	20	300

Perforations:
Type perforation Saw Cut
Size perforation 1/8
From 240 feet to 280 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout
Gravel Packed: [X] Yes [ ] No
From 50 feet to 300 feet

9. **WATER LEVEL**
Static water level 200 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon Nv. 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2212
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 03/20/2003

USE ADDITIONAL SHEETS IF NECESSARY