

Log No. 89476  
 Permit No. 0860  
 Basin 0860

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 45044

1. OWNER BILL CALLOS ADDRESS AT WELL LOCATION 5722 Ursula Ct.  
 MAILING ADDRESS 4400 Lakeside Drive 5722 Ursula Ct.  
Reno, Nevada 89509 Sun Valley, Nevada 89433  
 2. LOCATION NW 1/4 SW 1/4 Sec 13 T 20N N/S R 19 E Washoe County  
 PERMIT NO. 088-220-32 Sun Valley  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

| Material                                   | Water Strata | From | To  | Thick-ness |
|--|--------------|------|-----|------------|
| Decomposed Granite                         |              | 0    | 24  | 24         |
| Weathered granite                          |              | 24   | 40  | 16         |
| Decomposed granite soft with clay streaks  |              | 40   | 47  | 7          |
| Weathered granite                          |              | 47   | 60  | 13         |
| Soft zone, decomposed granite (app 10 GPM) | X            | 60   | 71  | 11         |
| Weathered granite                          |              | 71   | 81  | 10         |
| GRay granite                               |              | 81   | 110 | 29         |
| Fractured granite                          | X            | 110  | 118 | 8          |
| Weathered granite                          |              | 118  | 131 | 13         |
| Fractured granite                          | X            | 131  | 134 | 3          |
| Weathered granite                          |              | 134  | 138 | 4          |
| Fractured granite                          | X            | 138  | 140 | 2          |
| Weathered granite (hard)                   |              | 140  | 145 | 5          |

8. WELL CONSTRUCTION  
 Depth Drilled 145 Feet Depth Cased 145 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 Inches 0 Feet 100 Feet  
8 5/8 Inches 100 Feet 145 Feet  
 Inches Feet Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 6 5/8              |                     | .188                    | 0           | 145       |

Perforations: factory sawed slot  
 Type perforation  
 Size perforation 3/32 x 3 x 5 around  
 From 110 feet to 140 feet  
 From feet to feet  
 From feet to feet  
 From feet to feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 100 feet  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 100 feet to 145 feet

9. WATER LEVEL  
 Static water level 48 feet below land surface  
 Artesian flow 25+ G.P.M. P.S.I.  
 Water temperature cold °F Quality clear

Date started April 2, 2003, 19  
 Date completed April 3, 2003, 19

7. WELL TEST DATA

| TEST METHOD:   | G.P.M.     | Draw Down (Feet Below Static) | Time (Hours) |
|--|------------|-------------------------------|--------------|
| <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift | <u>25+</u> |                               |              |

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WAYNE DRILLING, INC. Contractor  
 Address P.O. BOX 12370 Contractor  
RENO, NEVADA 89510  
 Nevada contractor's license number 0022549  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 923  
 Division of Water Resources, the on-site driller  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date April 7, 2003