

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 89497  
 Permit No. 17152  
 Basin 071

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 50213a

1. OWNER Gary & Terri Tompkins Family Trust  
 MAILING ADDRESS 9200 S. Beechcraft Blvd  
Winnemucca, NV 89445

ADDRESS AT WELL LOCATION 9200 S. Beechcraft Blvd.  
 Well #2

2. LOCATION SE 1/4 NE 1/4 Sec. 26 T 35N N/S R 37E E Humboldt County  
 PERMIT NO. 17152  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
This is the original well on this property which was drilled in the late 1950.				
This well had caved in and the casing had lots of holes rusted thru. We perf the well from 5 ft. to 50 ft. We dare not go inside other casing because it was so bad.				
While pulling pump a portion of the casing came up with the bowls. This well was caved in to 200 ft.				
Set trimmie pipe and pumped 26,000# of neat cement w/4% bentonite				
<b>ABANDONMENT</b>				

8. WELL CONSTRUCTION  
 Depth Drilled \_\_\_\_\_ Feet Depth Cased \_\_\_\_\_ Feet

HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16				

Perforations:  
 Type perforation Holt perforator  
 Size perforation 1/8 x 1

From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 195  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 76 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc.  
 Contractor  
 Address 4675 W. Winnemucca Blvd  
 Contractor  
Winnemucca, Nevada 89445

Nevada contractor's license number issued by the State Contractor's Board 015234

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1154

Signed Terri Tompkins  
 By driller performing actual drilling on-site or contractor

Date 3/21/03

7. WELL TEST DATA

TEST METHOD: G.P.M.	TEST METHOD:		Time (Hours)
	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	
	Draw Down (Feet Below Static)		

RECEIVED  
 MAR 24 PM 2:18  
 STATE ENGINEERS OFFICE

Date started 3/7/03, 19  
 Date completed 3/7/03, 19