


STATE OF NEVADA  
 DIVISION OF WATER RESOURCES



OFFICE USE ONLY

Log No. **89503**  
 Permit No. **73099**  
 Basin **042**

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **50043**

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

1. OWNER **BILL RODRIGUEZ**  
 MAILING ADDRESS **P.O. BOX 515**  
**WELLS, NV 89835**

ADDRESS AT WELL LOCATION **5 MILES SOUTH OF WELLS,**  
**NV OFF HWY 93**

2. LOCATION **NE** 1/4 **NW** 1/4 Sec. **27** T **37N**  
 PERMIT NO. **NS** Issued by Water Resources  
**008-340-010** Parcel No.

N/S R **62E** E **ELKO** County  
**TRACT OF LAND** Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOPSOIL		0	2	2
SILTSTONE & SOME SMALL GRAVEL		2	100	98
SILTSTONE W/ SOME HARD LAYERS		100	110	10
SILTSTONE & LARGE GRAVEL	115	110	120	10
GRAVEL		130	140	20

8. WELL CONSTRUCTION

Depth Drilled **140** Feet Depth Cased **140** Feet

HOLE DIAMETER (BIT SIZE)

	From	To	Feet	Feet
<b>10 5/8</b> Inches	0	140	Feet	Feet
Inches			Feet	Feet
Inches			Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<b>6 5/8</b>	<b>13</b>	<b>.188</b>	<b>+1</b>	<b>140</b>

Perforations:  
 Type perforation **MILLSLOT**  
 Size perforation **3/16 X 3**

From	feet to	feet
<b>120</b>	<b>140</b>	<b>140</b>

Surface Seal:  Yes  No  
 Depth of Seal **50**  
 Placement Method:  Pumped  Poured  
 Seal Type:  Neat Cement  Cement Grout  Concrete Grout

Gravel Packed:  Yes  No  
 From **50** feet to **140** feet

RECEIVED  
 03 APR 15 AM 11:21  
 STATE ENGINEERS OFFICE

Date started **3/18/2003**  
 Date completed **3/19/2003**

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<b>70</b>		<b>4</b>

9. WATER LEVEL  
 Static water level **93** feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name **HACKWORTH DRILLING, INC** Contractor  
 Address **P.O. BOX 850** Contractor  
**ELKO, NV 89803**  
 Nevada contractor's license number issued by the State Contractor's Board **020582**  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1689**  
 Signed *[Signature]*  
 By driller performing actual drilling on-site or contractor  
 Date **3/20/2003**