WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 89549
Permit No.
Basin 089

NOTICE OF INTENT NO. 48378

1. OWNER Ralph Smith
MAILING ADDRESS 2190 Chukar Dr.
Washoe Valley, NV 89704

ADDRESS AT WELL LOCATION 2190 Chukar Dr.

2. LOCATION NW 1/4 NE 1/4 Sec. 31 T 17N N/S R 20E E Washoe County
PERMIT NO. Issued by Water Resources
050-363-08 Parcel No.
Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
We abandoned this well by first perforating the casing from approximately 170' to 80' at four around and at one foot intervals. From 50', we continued to top of well as the well had no surface seal that we could detect. We then pumped approximatley 2.5 yards of neat cement mixed 5.2 gallons of water per sack of cement using a tremie pipe and pumped from the bottom to the surface. We cut off the top 2 feet of casing.				

RECEIVED 03 FEB 13 AM 11:20 STATE ENGINEER'S OFFICE

Date started 2/10/2003, 19__
Date completed 2/11/2003, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 190 Feet Depth Cased 190 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	)1	190

Perforations:
Type perforation Mills Knife
Size perforation Puncture
From 170 feet to 80 feet
From 50 feet to 0 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 130 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. Contractor
Address 1600 Mt. Rose Hwy Contractor
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce MacKay
By driller performing actual drilling on-site or contractor
Date 2/1/03

USE ADDITIONAL SHEETS IF NECESSARY