

OFFICE USE ONLY
 Log No. 89635
 Permit No. _____
 Basin 16a

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23848

1. OWNER JOE + MARLA QUERCIA ADDRESS AT WELL LOCATION 5881 S HEOMAN ST PAHRUMP
 MAILING ADDRESS _____

2. LOCATION SE 1/4 SE 1/4 Sec 11 T 21 N/S R 54 E M/E County _____
 PERMIT NO. 47061-05 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>DIRT</u>		<u>0</u>	<u>4</u>	
<u>ALUMIUM</u>		<u>5</u>	<u>355</u>	
<u>WATER</u>	<u>260</u>			
<u>WATER</u>	<u>303</u>			
<u>WATER</u>	<u>330</u>			

DCNR/DWR RECEIVED
 JUN 09 2003

8. WELL CONSTRUCTION
 Depth Drilled 355 Feet Depth Cased 355 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 355 Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>PVC</u>	<u>SCH 40</u>	<u>0</u>	<u>355</u>

Perforations:
 Type perforation FACTORY SLOT
 Size perforation 0.20
 From _____ feet to _____ feet
 From 355 feet to 315 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 355 feet

9. WATER LEVEL
 Static water level 217 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 65.0 °F Quality good

7. WELL TEST DATA
 TEST METHOD: Bailer Pump Air Lift
 Date started April 27 10:03
 Date completed April 29 10:03

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Joe Ben Contractor
 Address PO Box 6678 PAHRUMP NV 89048 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 36415
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1650
 Signed Joe Ben
 By driller performing actual drilling on site or contractor
 Date MAY 5 - 2003