WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 89639
Permit No. 24037
Basin 212

NOTICE OF INTENT NO. 25171

1. OWNER LVVWD W34 Las Vegas Valley Water Dist
MAILING ADDRESS 1001 S. Valley View Las Vegas NV 89150
ADDRESS AT WELL LOCATION North Well Field At Alta And Valley View

2. LOCATION SW ¼ SW ¼ Sec. 29 T. 20S N/S R. 61E E. 32 County
PERMIT NO. 24037 Issued by Water Resources | Parcel No. | N/A Subdivision Name
LOG# 27142

3. WORK PERFORMED
☐ New Well ☐ Replace ☒ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
2-10-03. Set up rig, rig up, rig up Bailer, tag Bottom (580'), Bailed out from 580' to 560' Cleaned out 70'				
2-11-03 It was a Bridge, push Bridge down to 857' Bailed out to 867' (cleaned out 10'). I can't go down with Bailer around 570' to 580' shut down.				
2-12-03 Video well around 575' Casing is Broke.				
3-19-03 Rig up, tag Bottom 830'. Bailed out from 830' to 890'				
3-20-03 Bailed out from 890' to 895'. Bailer was stuck, Release Bailer after 2 HRS.				

DCNR/DWR RECEIVED MAR 19 2003 LAS VEGAS OFFICE

Date started 2-10-2003, 19
Date completed 3-28-2003, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
~~4300~~		

8. WELL CONSTRUCTION
Depth Drilled 1000 Feet Depth Cased 1000 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
16" Inches	0 Feet	1000 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16"		1/4	0	1000

Perforations:
Type perforation
Size perforation
From 550' feet to 850 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100'
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 75 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name B-L-Webers Group Inc (Contractor)
Address 4145 Arctic Spring Ave (Contractor)
Las Vegas NV 89115
Nevada contractor's license number issued by the State Contractor's Board 035639
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2221
Signed David E. Mendez
By driller performing actual drilling on site or contractor
Date 4-2-03

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627