

OFFICE USE ONLY
 Log No. 39696
 Permit No. 025
 Basin

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 51308

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

1. OWNER Stu Brown ADDRESS AT WELL LOCATION Hanging Rock Camp
 MAILING ADDRESS 106 E ADAMS SUITE 212
Carson City NV

2. LOCATION SE 1/4 SW 1/4 Sec 25 T 42 R 22 E Washoe County
 PERMIT NO. 68247 2061-030-17 Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Topsail		0	2	2
Clay + Rock		2	30	28
White Clay		30	50	20
Black Rock		50	60	10
White Clay		70	180	110
Coarse Sand		180	200	20
Black Rock		200	220	20
Brown Clay		220	230	10
Chipped Black Rock		230	270	40
Coarse Rock		270	310	40
Fine Gravel	Yes	310	320	10
Hard Rock		320	330	10

8. WELL CONSTRUCTION
 Depth Drilled 330 Feet Depth Cased 330 Feet

HOLE DIAMETER (BIT SIZE)
 From 105/8 Inches To 330 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>65/8</u>	<u>10</u>	<u>188</u>	<u>+</u>	<u>330</u>

Perforations:
 Type perforation Factory Cut
 Size perforation 3/32x1/4
 From 290 feet to 330 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 100 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured

Gravel Packed: Yes No
 From 100 feet to 330 feet

9. WATER LEVEL
 Static water level 250 feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature 60.1 °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Fred Anderson + Sons Contractor
 Address 10760 Grass Valley Rd
Winn NV 89445 Contractor
 Nevada contractor's license number issued by the State Contractor's Board RO 021467
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083
 Signed Chris K...
 By driller performing actual drilling on site or contractor
 Date April 8 2003

Date started April 3 2003
 Date completed April 8 2003

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
		<u>5</u>

RECEIVED
 MAY 13 AM 10:32
 STATE ENGINEERS OFFICE