

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 89697
 Permit No. _____
 Basin 008

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 46586

1. OWNER STW Brown ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 106 E Adams Suite 22 Coyote Camp
Carson City NV
 2. LOCATION SW 1/4 NW 1/4 Sec 33 T 43 N/S R 22 E Washoe County
 PERMIT NO. 08248 061-070-15 Subdivision Name _____
Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Topsoil		0	3	3
Boulders		3	20	17
Sand		20	25	5
Gravel + Sand		25	30	5
Hard Black Rock		30	161	71
Sand + Gravel	yes	101	145	44
Clay		145	150	5

8. WELL CONSTRUCTION
 Depth Drilled 150 Feet Depth Cased 147 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 150 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>10</u>	<u>1.55</u>	<u>71</u>	<u>147</u>

Perforations:
 Type perforation Factory cut
 Size perforation 3/32 x 14
 From 117 feet to 147 feet
 _____ feet to _____ feet
 _____ feet to _____ feet
 _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Depth of Seal 50 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 50 feet to 147 feet

9. WATER LEVEL
 Static water level 68 feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature 100.1 °F Quality Fair

Date started March 28 2003
 Date completed March 31 2003

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>13</u>		<u>4</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Fred Anderson + Sons Drilling Contractor
 Address 10760 Grass Valley Rd Contractor
Winn NV 89445
 Nevada contractor's license number issued by the State Contractor's Board 021467
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date March 31 03

RECEIVED
 MARCH 13 AM 10:32
 STATE ENGINEERS OFFICE