COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 89698
Permit No.
Basin 103

NOTICE OF INTENT NO. 46425

1. OWNER DONNETTE BARRETO
MAILING ADDRESS P.O. Box 1327
CARSON CITY, NV 89701

ADDRESS AT WELL LOCATION #1 RIVER VISTA RD
DAYTON, NV 89443

2. LOCATION NW ¼ NE ¼ Sec 35 T 16 N R 21 E LYON County

PERMIT NO. (Issued by Water Resources) 19-622-13 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| BROWN HARD PAN | | 0 | 3 | 3 |
| BLACK SLATE | | | | |
| VERY FRACTURED | | 3 | 37 | 34 |
| HARD SLATE BLACK | | 37 | 91 | 54 |
| VERY HARD OBSIDIAN | | 91 | 165 | 74 |
| SLATE | | | | |
| FRACTURED GRAVEL | xxx | 165 | 220 | 55 |
| OBSIDIAN GRAVELS | | | | |

RECEIVED 03 MAY 15 AM 11:11 STATE ENGINEERS OFFICE

Date started 4/25, 20 03
Date completed 4/29, 20 03

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 22 | 65 | 3 HRS |

8. WELL CONSTRUCTION

Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 10 3/4 Inches | 0 Feet | 220 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 13.03 | .188 | 0 | 220 |

Perforations:
Type perforation FACTORY MILL SLOT
Size perforation 3X 3/32
From 200 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 100 ☒ Neat Cement
Placement Method: ☒ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 100 feet to 200 feet

9. WATER LEVEL
Static water level 60 feet below land surface
Artesian flow G.P.M ~~22~~ P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLLING & PUMPS INC. (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 55548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
Signed [signature]
By driller performing actual drilling on site or contractor
Date 5/13/03

(Rev 3-91) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk, Inc. · Dallas, Texas · (214) 340-9429