

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES

OFFICE/USE ONLY  
 Log No. 89708  
 Permit No. \_\_\_\_\_  
 Basin 162

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **24897**

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

1. OWNER **RONALD JOHNSON** ADDRESS AT WELL LOCATION **5661 E. SANTIVITO**  
 MAILING ADDRESS **5661 E. SANTIVITO**  
**PAHRUMP, NV 89048**  
 2. LOCATION **SW** 1/4 **SE** 1/4 Sec. **16** T **21S** N/S R **54E** E **NYE** County  
 PERMIT NO. \_\_\_\_\_ Parcel No. **45-151-09** **KELLOGG HILLSIDE ESTATES**  
 Issued by Water Resources Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND AND GRAVEL		0	80	80
CALICHE	WB	80	100	20
GRAVEL		100	130	30
GRAVEL	WB	130	190	60
GRAVEL		190	220	30
GRAVEL	WB	220	300	80
PLUG OLD WELL PERFORATE WELL AND PUMP NEAT CEMENT THROUGH TRIMMIE PIPE TO BOTTOM				
DCNR/DWR RECEIVED				
JUN 23 2003				
LAS VEGAS OFFICE				

8. WELL CONSTRUCTION  
 Depth Drilled **200** Feet Depth Cased **200** Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
**10.25** Inches **0** Feet **300** Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	3.63	.250	0	300

Perforations:  
 Type perforation **SAW CUT**  
 Size perforation **1/8 X 3**  
 From **140** feet to **200** feet  
 From **220** feet to **280** feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal **50**  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From **50** feet to **300** feet

9. WATER LEVEL  
 Static water level **95** feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. **2.5**  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **GREAT BASIN DRILLING CO. OF NEVADA, INC.** Contractor  
 Address **P.O. BOX 4220** Contractor

**PAHRUMP, NV, 89048**  
 Nevada contractor's license number issued by the State Contractor's Board **47333**  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller, **2063**  
 Signed *Ron Toray*  
 By driller performing actual drilling on-site or contractor  
 Date **5/30/2003**

Date started **4/28/2003**, 19\_\_\_\_  
 Date completed **5/2/2003**, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			