WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 89786
Permit No.
Basin 212

NOTICE OF INTENT NO. 24936

1. OWNER KNUDSEN C FAMILY TRUST
MAILING ADDRESS 3675 Greenerest Las Vegas, NV
ADDRESS AT WELL LOCATION Alpine Ridge Way & Vira St. Las Vegas, NV

2. LOCATION NW ¼ NE ¼ Sec. 01 T. 19 N/S R. 59 E. CLARK County
PERMIT NO. | Issued by Water Resources | 126-01-501-005 Parcel No. | ROSSUM REALITY Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Abandon 1-6" domestic well				
Depth 561'				
Static water Level 470'				
Perforate from 350' to 560'				
Trimmie cement from 560' to 318'				
Filled with pea gravel 318' to 20'				
20' to 0' filled with 3/4" rock 5 sack mix.				

DCNR/DWR
RECEIVED
JUN 2 ? 2003
LAS VEGAS OFFICE

Date started 6/11/03, 20
Date complated 6/20/03, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 470' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name ALLEN DRILLING INC. Contractor
Address 4015 WEST TOMPKINS Contractor
LAS VEGAS, NV 89103
Nevada contractor's license number issued by the State Contractor's Board 18917
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1301
Signed Fred B Allen III
By driller performing actual drilling on site or contractor
Date 6/25/03

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627