

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24720

1. OWNER Gio Tech Builders ADDRESS AT WELL LOCATION Tenaya & Wiggam  
MAILING ADDRESS P.O. 97932 8515 S Tenaya  
L.V., NV 89197 Clark County  
2. LOCATION N 6 1/4 SW 1/4 Sec. 15 T. 22 N/S R. 20 E  
PERMIT NO. 176 15 301 032 Subdivision Name \_\_\_\_\_  
Issued by Water Resources Parcel No. \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Small Gravel</u>		<u>0</u>	<u>10</u>	<u>10</u>
<u>Clay-Sand &amp; Gravel</u>		<u>10</u>	<u>150</u>	<u>140</u>
<u>Cemented Gravel</u>		<u>150</u>	<u>190</u>	<u>40</u>
<u>Clay Gravel Boulders</u>		<u>190</u>	<u>330</u>	<u>140</u>
<u>Cemented Gravel</u>		<u>330</u>	<u>380</u>	<u>50</u>
<u>Clay Gravel</u>		<u>380</u>	<u>470</u>	<u>90</u>
<u>Clay</u>	<input checked="" type="checkbox"/>	<u>470</u>	<u>575</u>	<u>105</u>
<u>Brown Clay Gravel</u>	<input checked="" type="checkbox"/>	<u>575</u>	<u>725</u>	<u>150</u>

DCNR/DWR  
RECEIVED  
JUL 23 2003  
LAS VEGAS OFFICE

8. WELL CONSTRUCTION  
Depth Drilled 725 Feet Depth Cased 720 Feet

HOLE DIAMETER (BIT SIZE)  
From 10 Inches To 0 Feet 725 Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6.9m</u>	<u>F480</u>		<u>1</u>	<u>720</u>
<u>8 5/8</u>	<u>188</u>		<u>5ft.</u>	<u>189m</u>

Perforations:  
Type perforation saw  
Size perforation 1/2 X 12  
From 620 feet to 720 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 50+  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
From 59.5 feet to 50 feet

Date started 6-9-03, 20  
Date completed 6-19-03, 20

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>40</u>		<u>2 HR</u>

9. WATER LEVEL  
Static water level 525 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature COOL °F Quality OK

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Kedding Drilling Contractor  
Address 3955 Blue Diamond Rd #4 Contractor  
Las Vegas, NV 89139  
Nevada contractor's license number issued by the State Contractor's Board 38155  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 167  
Signed F. J. Mitchell  
By driller performing actual drilling on site or contractor  
Date \_\_\_\_\_