

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 44615

Washoe County, Dept. of Water Resources
 1. OWNER MAILING ADDRESS: 4930 Energy Way, Reno, NV 89502
 ADDRESS AT WELL LOCATION: Estates Rd. and Hillview Dr.
 2. LOCATION: SW 1/4 SW 1/4 Sec. 2 T. 20 N. S. R. 19 E. Washoe County
 PERMIT NO. RECHARGE R-009 552-030-01
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED: New Well, Replace, Recondition, Deepen, Abandon, Other
 4. RECHARGE PROPOSED USE: Domestic, Municipal/Industrial, Irrigation, Monitor, Test, Stock
 5. WELL TYPE: Cable, Rotary, RVC, Air, Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Aluvium/sand/brwn		-0-	40	
Solid Granite, no Weathering		40	136	
Fractured Granite no Weathering		136	142	
First H ² O Zone Fractured		142	143	
Granite, Very Consolidated		143	150	
Small Weathered Zone		150	155	
Fracture no Weathered H ² O Zone		155	160	
Major Fracturing No Weathered Granite		160	180	
Multiple Fracturing None Weathered Granite		180	320	
Weathered Granite Very Fine Sand		320	340	
Consolidated Fractured Granite		340	350	

8. WELL CONSTRUCTION
 Depth Drilled: 405 Feet, Depth Cased: 400 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
 14-3/4 inches -0- Feet 405 Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8"	7.5	.290	400	160
8"	22.36	.250	160	-0-

Perforations:
 Type perforation: S.S. Wirewrap
 Size perforation: .080
 From 400 feet to 160 feet
 From feet to feet
 From feet to feet
 From feet to feet

Surface Seal: Yes No Seal Type: Neat Cement, Cement Grout, Concrete Grout
 Depth of Seal: 0-137
 Placement Method: Pumped, Poured
 Gravel Packed: Yes No
 From 405 feet to 137 feet

9. WATER LEVEL
 Static water level: 70 feet below land surface
 Artesian flow: G.P.M. P.S.I.
 Water temperature: °F Quality

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name: Beylik Drilling, Inc. Contractor
 Address: 555 S. Harbor Blvd. Contractor
 La Habra, CA 90631-6124
 Nevada contractor's license number issued by the State Contractor's Board: 0007055A
 Nevada driller's license number issued by the Division of Water Resources: on-site driller 2175
 Signed: [Signature] By driller performing actual drilling on site or contractor
 Date: 5/15/03

Date started: February 19, 2003, 19
 Date completed: April 27, 2003, 19

7. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input checked="" type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
		16 hours	

