

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25258

1. OWNER L.V.V.W.D ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 293 S. Valley View 293 S. Valley View
LAS VEGAS, NV LAS VEGAS, NV
 2. LOCATION SE 1/4 SW 1/4 Sec 29 T 20 N/S R. 61 E CLARK County
 PERMIT NO. 139-29-401-001 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE Cable Rotary RVC
 Air Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Silty SAND</u>		<u>0.0</u>	<u>11.0</u>	<u>11.0</u>
<u>Silty SAND w/clay</u>		<u>11.0</u>	<u>16.0</u>	<u>5.0</u>
<u>clay w/SAND</u>		<u>16.0</u>	<u>30.0</u>	<u>14.0</u>
<u>sandy clay w GRAVEL</u>		<u>30.0</u>	<u>35.0</u>	<u>5.0</u>
<u>silty sand w/GRAVEL</u>		<u>35.0</u>	<u>55.0</u>	<u>20.0</u>

8. WELL CONSTRUCTION
 Depth Drilled 55 Feet Depth Cased 55 Feet
 HOLE DIAMETER (BIT SIZE)
 From 1 1/2 Inches To 0 Feet 55 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4.250</u>		<u>sch 40 PVC</u>	<u>30.0</u>	<u>00</u>

 Perforations:
 Type perforation MACHINE SLOTTED
 Size perforation .020
 From 55.0 feet to 30.0 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 2' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 55.0 feet to 25.0 feet

Date started 7/7, 2003
 Date completed 7/8, 2003

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL
 Static water level 25.69 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EAGLE DRILLING Contractor
 Address 7150 PLACID ST Contractor
LAS VEGAS, NV 89119
 Nevada contractor's license number issued by the State Contractor's Board 51266
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2202
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date 7-15-03