WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 90009
Permit No.
Basin 212

NOTICE OF INTENT NO. 24909

1. OWNER The Esslinger Family Trust
MAILING ADDRESS 12932 N. 136th St Scottsdale, AZ 85259
ADDRESS AT WELL LOCATION 5525 W Charleston Las Vegas, NV

2. LOCATION NE ¼ NW ¼ Sec. 1 T. 21 N/S R 60 E/W Clark County
PERMIT NO. (Issued by Water Resources) Parcel No. 163-01-103-003 Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
silty sand w/ gravel		1'	10.5'	9.5
silty sand, brown w/ fines trace				
caliche		10.5'	18.5'	8
poorly graded sand		18.5'	23'	4.5
sandy clay w/ gravel		23'	33.5'	10.5
gravelly sand		33.5'	39'	5.5
cemented soil		39'	41'	2
well graded gravelly sand		41'	44'	3
silty clay trace gravel		44'	50'	6
silty clay, trace gravel w/ paint odor		50'	53.5'	3.5
cemented soil		53.5'	60.5'	7
cemented soils w/ gravel		60.5'	80'	19.5

DCNR/DWR
RECEIVED
JUL 28 2003
LAS VEGAS OFFICE

Date started June 12, 2003
Date completed June 12, 2003

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 75 Feet Depth Cased 75 Feet

HOLE DIAMETER (BIT SIZE)
9 Inches From 75 Feet To 75 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	PVC	Sch 40	0	75

Perforations:
Type perforation Factory Slot
Size perforation .020
From 45 feet to 75 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 40 to surface
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 40 feet to 75 feet

9. WATER LEVEL
Static water level 63 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) Elite Drilling Inc
Address (Contractor) 5115 S. Industrial Rd #104 Las Vegas, NV 89118
Nevada contractor's license number issued by the State Contractor's Board 0054931
Nevada driller's license number issued by the Division of Water Resources, the on site driller M-1869
Signed (By driller performing actual drilling on site or contractor)
Date 7-23-03

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627