FOR 4 WELLS (INTENT CARD WAS FOR 8 WELLS - REMAINING 4 WELLS WILL NOT BE DRILLED)

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 90016
Permit No.
Basin 212

NOTICE OF INTENT NO. 24526

1. OWNER Bellagio
MAILING ADDRESS P.O. Box 7700
Las Vegas, NV.

ADDRESS AT WELL LOCATION 3600 Las Vegas Blvd. S.
Las Vegas, NV.

2. LOCATION NE ¼ ¼ Sec. 20 T. 21S N/S R. 61 E. Clark County
PERMIT NO. DW 1157 (Issued by Water Resources) 162-20-501-005 (Parcel No.) N/A (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☒ Other dewatering

4. PROPOSED USE Dewater
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill		-0-	12	12
Caliche		12	27	15
Brown Clay		27	60	33

DCNR/DWR
RECEIVED
JUL 11 2003
LAS VEGAS OFFICE

Date started April 28, 2003
Date completed May 12, 2003

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 60 Feet Depth Cased 60 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10-5/8 Inches		-0- Feet	60 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	PVC		+2	60

Perforations:
Type perforation Mill Slot
Size perforation 1/8 x 2
From -0- feet to 60 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 25
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout Bentonite
Gravel Packed: ☒ Yes ☐ No
From 25 feet to 60 feet

9. WATER LEVEL
Static water level 23 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Thompson Drilling Co., Inc. (Contractor)
Address 7227 Hauck St. (Contractor)
Las Vegas, NV. 89118
Nevada contractor's license number issued by the State Contractor's Board 0004286A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2120
Signed Richard K. Thompson (By driller performing actual drilling on site or contractor)
Date July 10, 2003

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627