

OFFICE USE ONLY  
 Log No. 90030  
 Permit No. \_\_\_\_\_  
 Basin 162  
 NOTICE OF INTENT NO. 25157

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Spalding Construction ADDRESS AT WELL LOCATION 1380 E. Cavalry St.  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION NE 1/4 NW 1/4 Sec. 35 T. 20-S N/S R. 53 E. Nye County \_\_\_\_\_  
 PERMIT NO. 42-691-19 Calvada Valley Ut:3 Bk:25 Lt:4  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface		0	4	4
BrownClay/Gran. Caliche		4	13	9
BrownClay		13	21	8
Brown Clay/Caliche		21	30	9
Limestone		30	34	4
BrownClay/Caliche	X	34	115	81
BrownClay	X	115	143	28
BrownClay/Caliche	X	143	160	17

8. WELL CONSTRUCTION  
 Depth Drilled 160 Feet Depth Cased 160 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 Inches To 0 Feet 160 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	160

Perforations:  
 Type perforation Torch Cut  
 Size perforation 1/4" width 8" long  
 From 1.20 feet to 1.60 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Cement Grout  
 Placement Method:  Pumped  Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 5.0 feet to 160 feet

DCNR/DWR  
 RECEIVED  
 JUL 22 2003  
 LAS VEGAS OFFICE

9. WATER LEVEL  
 Static water level 46 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started July 15, 2003  
 Date completed July 15, 2003

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	4	1/4

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name JIM PIKE WELL DRILLING, LLC. Contractor  
 Address P.O. BOX 56  
PAHRUMP, NV. \*9041 Contractor  
 Nevada contractor's license number 17563A  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 1324  
 Division of Water Resources, the on-site driller  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date July 18, 2003