

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24970

1. OWNER UNIVERSITY NEVADA LV FOUNDATION ADDRESS AT WELL LOCATION Russell Rd. & New Beginning
 MAILING ADDRESS 4503 S. MARYLAND PKWY LAS VEGAS, NV
 2. LOCATION SE 1/4 NE 1/4 Sec. 34 T. 21 N/S R. 62 E. CLARK County
 PERMIT NO. DW1162 161-34-510-003 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other Dewater
 4. PROPOSED USE Dewater
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>1-Dewater wells</u>				
<u>#4</u>				
<u>River rock & alluvium</u>		<u>0</u>	<u>14</u>	
<u>River rock & coarse sand</u>		<u>14</u>	<u>22</u>	
<u>Brown silt</u>		<u>22</u>	<u>30</u>	

8. WELL CONSTRUCTION
 Depth Drilled 30 Feet Depth Cased 30 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
24 Inches _____ Feet 30 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>14</u>	<u>36.71</u>	<u>1.250</u>	<u>0</u>	<u>30</u>

Perforations:
 Type perforation Machine
 Size perforation 1/4" x 2 1/2" x 3 rows @ 13
 From 10 feet to 30 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 12' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
ALLEN DRILLING INC.

Name _____ Contractor
 Address 4013 W. Tompkins Ave. Contractor
LAS VEGAS, NV 89103
 Nevada contractor's license number issued by the State Contractor's Board 18917
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1301
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 8/4/03

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)