WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
L No. 90079
Permit No.
Basin 107

NOTICE OF INTENT NO. 48618

OWNER Don Renner
MAILING ADDRESS PO Box 42
Wellington, NV 89444

ADDRESS AT WELL LOCATION 295 Hudson Aurora
Smith
Valley

2. LOCATION NE 1/4 NE 1/4 Sec. 4 T 10N N/S R 24E E Lyon County
PERMIT NO. 65468 (Issued by Water Resources) | 10-601-10 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
sand & silt		0	70	
sand & cobbles		70	88	18
sand & gravel		88	94	6
coarse sand		94	112	18
clay w/sand		112	118	6
hard sand		118	151	33
sand		151	163	12
silty sand w/clay		163	174	11
sandy silt w/s gravel		174	224	50
cemented gravel		224	256	32
cobbles & clay		256	296	40
sand & clay mix		296	370	74

Date started 5/27/03, 19__
Date completed 5/29/03, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
75		6 hrs.

8. WELL CONSTRUCTION
Depth Drilled 370 Feet Depth Cased 360 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
15 Inches	0 Feet	370 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8-5/8		.188	+1	160

Perforations:
Type perforation mill slot
Size perforation .90
From 160 feet to 360 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 360 feet

9. WATER LEVEL
Static water level 160 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc. (Contractor)
Address 4675 W. Winnemucca Blvd (Contractor)
Winnemucca, Nevada 89445

Nevada contractor's license number issued by the State Contractor's Board 015234

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1713

Signed [signature] (By driller performing actual drilling on-site or contractor)

Date 5/31/03