



Log No. 98080
 Permit No. _____
 Basin. 107

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 48663

1. OWNER Perry Urton ADDRESS AT WELL LOCATION 241 CHAPARRAL
 MAILING ADDRESS 1020 Sierra Vista Av Smith, NV
Gardnerville, NV 89460
 2. LOCATION NW 1/4 NW 1/4 Sec. 22 T 11 N/S R 24 E LYON County
 PERMIT NO. 09-152-03 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
BROWN SAND + D. GR		0	50	50
BROWN CLAY		50	70	20
GREY CLAY		70	90	20
GREY CLAY + SAND		90	100	10
SAND		100	160	60
SAND + GRAVEL		160	200	40

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet
 HOLE DIAMETER (BIT SIZE)
10 5/8 Inches From 0 Feet To 200 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>		<u>0.189</u>	<u>0</u>	<u>200</u>

Perforations:
 Type perforation FACTORY
 Size perforation _____
 From 180 feet to 200 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 200 feet to 50 feet

9. WATER LEVEL
 Static water level 89 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

Date started 2-12-03, 20_____
 Date completed 2-13-03, 20_____
 7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>50T</u>		<u>2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Nevada Pump & Drilling
 Address P.O. Box 227
Dayton, NV 89403
 Nevada contractor's license number issued by the State Contractor's Board 46357
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2187
 Signed Thomas Evans
 By driller performing actual drilling on site or contractor
 Date Feb. 16, 2003