WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 90094
Permit No.
Basin 227

NOTICE OF INTENT NO. 24289

1. OWNER Nye County
MAILING ADDRESS 1210 E. Basin Rd., Suite 6
Pahrump, NV 89060

ADDRESS AT WELL LOCATION
NC-EWDP-29P

2. LOCATION NE ¼ NW ¼ Sec. 3 T 15 N/S R 49 E Nye County
PERMIT NO. Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Allumivum (SW-SM w grvl)Qal	no	0	235	235
Alluvium (SW-SM & SC w/grvl)Qal	no	235	320	85
Rhyolite Tuffs (paint brush group Tp) "flowing sand" 700-720	yes	320	791	471

Date started 7/8, 2003
Date completed 7/15, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
none			

8. WELL CONSTRUCTION
Depth Drilled 790.7 Feet Depth Cased 410.6 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12	Inches	0	Feet	61.5	Feet
6 1/4	Inches	61.5	Feet	790.7	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.9	0.188	0	58
2 3/8	0.95	0.218	0	410.7

Perforations:
Type perforation slotted
Size perforation 0.020"
From 340 feet to 400 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 335.8
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout bentonite grout
Gravel Packed: ☐ Yes ☐ No
From 335.8 feet to 404.8 feet

9. WATER LEVEL
Static water level 349 feet below land surface
Artesian flow N/A G.P.M. P.S.I.
Water temperature 84.2 °F @702' Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eklund Drilling Co., Inc. Contractor
Address P. O. Box 2748 Contractor
Elko, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 0030823
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1819-M
Signed Greg Secrist
By driller performing actual drilling on site or contractor
Date 8/5/03

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627