WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 90103
Permit No.
Basin 107

NOTICE OF INTENT NO. 47914

1. OWNER JERRY Attoway
MAILING ADDRESS 3172 RAUCHER
SAN JOSE CA 95127

ADDRESS AT WELL LOCATION ARTESia Rd.
Smith, NEV 89430

2. LOCATION NE ¼ SE ¼ Sec 21 T 12 N/S R 23 E Lyon County
PERMIT NO. (Issued by Water Resources) Parcel No. 10-081-23 Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[X] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	3	3
Sandy Loam		3	35	32
Sm. Gravel		35	38	3
Brwn Clay		38	85	47
Sandy Brwn Clay				
Hard Brn Clay		85	97	12
Coarse Sand	yes	97	102	5
Sandy Brwn Clay Pea gravel	yes	102	115	12
Sandy Brwn Clay	yes	115	137	22
Coarse Sandy	yes	137	142	5
Hard Brwn Clay		142	144	2
Sandy Brwn Clay	yes	144	165	21
Coarse Sand	yes	165	190	25
Coarse Sand	yes	190	205	15
~~Coarse Sand~~		~~190~~		
Coarse Sand	yes	205	220	15

Date started MARCH 15 2003
Date completed MARCH 20 2003

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [X] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	5 ft	5 HRS

8. WELL CONSTRUCTION
Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE) PER DRILLER

	From	To
10 5/8 ~~8 5/8~~ Inches	0 Feet	60 Feet
6 5/8 Inches	60 Feet	220 Feet
~~6 5/8~~ Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		188	0	220

Perforations:
Type perforation Factory SAW Slot
Size perforation 1/8 x 4
From 180 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 60 ft
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout
Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 70 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Edmund Miller Contractor
Address PO BOX 92 Contractor
Smith NEV 89430
Nevada contractor's license number issued by the State Contractor's Board 32166 A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718
Signed Edmund Miller By driller performing actual drilling on site or contractor
Date 3-21-03

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627