

OFFICE USE ONLY  
 Log No. 90105  
 Permit No. 257  
 Basin 257

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19693

1. OWNER WOODWARD-CLYDE CONSULTANTS ADDRESS AT WELL LOCATION CONTINENTAL BAKING CO.  
 MAILING ADDRESS 10370 Old Placerville Rd. Sut 1 1825 Glendale Ave  
Sacramento, CA. 95327-2505 Sparks, NV  
 2. LOCATION SW 1/4 NW 1/4 Sec 8 T 19N N/S R 20 E Washoe County  
 PERMIT NO. M/O #520 B-1/M W-1/SVW-1 Sparks  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other TUBEX 190

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Asphalt		0	4"	4"
Clayey sand w/gravel				
dk. br. 20% clay, loose				
damp 5-10% gravel				
cobbles to 10"x6"x5"		4"	2.2	1.8
Clayey sand, black damp				
firm 20-30% clay,				
trace cobble gravels		2.2	4	1.8
30 to 40% clay		4	5	1
Gravelly sand, brn.				
loose, damp, gvl. frgm				
to 1/2" size, 5% clay				
gvl to 25%		5	9	4
Sandy gravel, brn loose				
dry gvl subang. subrnd		9	12.8	3.4
Large boulder		12.8	14	1.4
As above, sandy gravel		14	15.5	1.5
Same, rounded cobbles				
3"x4"x3" size		15.5	20	5.5
Sand w/gravel, reddish				
brn. 10-15% subang.				
gravel to 4"x3"x3"		20	27.5	7.5
Same very moist to wet		at 25.5		
Gravel w/sand, greyish				
brn. ang-subang gvls				
to 3"x2" size, up to				
15%, wet loose		27.5	34	6.5
As above, gravel w/sand		at 31		

8. WELL CONSTRUCTION  
 Depth Drilled 34 Feet Depth Cased 31 Feet

HOLE DIAMETER (BIT SIZE)  
 From 0 To 34  
9 5/16 Inches 0 Feet 34 Feet  
 Inches Feet  
 Inches Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5" PVC		sch 40	0	33
1.5" PVC		sch	0	16
PVC end 7 locking cap				

Perforations:  
 Type perforation factory sawed slot  
 Size perforation .020x1 1/2x6 rows  
 From 14.5 feet to 16 w/1" feet  
 From 20 1/2 feet to 31 w/4" feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type: 0-11'  
 Depth of Seal 1' bentonite 11-12'  Neat Cement  
2 1/2' 17 1/2-19  Cement Grout 16-17 1/2'  
 Placement Method:  Pumped  Concrete Grout  
 Poured

Gravel Packed:  Yes  No #3 Monterey  
 From 12 to 16 feet to 19 to 34 feet

9. WATER LEVEL  
 Static water level 25.8 feet below land surface  
 Artesian flow not known G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_  
 Water temperature not kno F Quality not known

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Wayne Drilling, Inc. Contractor  
 Address P.O. Box 12370 Contractor  
Reno, NV 89510  
 Nevada contractor's license number 22549  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 908  
 Division of Water Resources, the on-site driller  
 Signed Wayne C. [Signature]  
 By driller performing actual drilling on site or contractor  
 Date July 1, 1992

Date started 3-9-92  
 Date completed 3-10-92

7. WELL TEST DATA

TEST METHOD:	TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
No test			