WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 90108
Permit No.
Basin 230

NOTICE OF INTENT NO. 25359

1. OWNER: Larry Weese
MAILING ADDRESS: 1654 W. Connestoga, Amargosa Valley, Nv. 89020
ADDRESS AT WELL LOCATION: 654 W. Connestoga, Amargosa Valley, Nv. 89020

2. LOCATION: S ¼ N ¼ NE ¼ Sec. 1 T. 17 N/S R. 48 E/W NYE County
PERMIT NO. (Issued by Water Resources) — Parcel No. 19-681-23 — Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
large gravel w/sand		0	25	25
compacted gravel		25	40	15
sand		40	60	20
white clay		60	70	10
limestone		70	75	5
brown clay		75	80	5
limestone		80	90	10
sand		90	100	10
gravel w/sand	1st	100	118	18
limestone		118	130	12
gravel w/sand		130	150	20
tan clay		150	195	45
limestone		195	200	5
sand w/clay layers	2nd	200	220	20
Bottom of Well			220	

DCNR/DWR
RECEIVED
AUG 18 2003
LAS VEGAS OFFICE

Date started 7/30/03, 19
Date completed 8/7/03, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
12¼	0	220

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	PVC		0	220
Surface Protective Casing:				
8	steel	.188	0	7

Perforations:
Type perforation: Machined
Size perforation: 6 R., .032 Screen
From 100 feet to 140 feet
From 200 feet to 210 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 220 feet

9. WATER LEVEL
Static water level 82' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor): Great Basin Drilling
Address (Contractor): P.O. Box 4220, Pahrump, Nv. 89041
Nevada contractor's license number issued by the State Contractor's Board: ~~2160~~ 047333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 2160
Signed: [signature] (By driller performing actual drilling on site or contractor)
Date: 8/8/03

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627