

Converted to domestic use RC 11-21-08

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA

OFFICE USE ONLY

DIVISION OF WATER RESOURCES

Log No. 90121
Permit No. 55033
Basin. 058

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34871

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

1. OWNER Dennis L. Carvise ADDRESS AT WELL LOCATION _____
MAILING ADDRESS HCG 1 Box 106
Battle Mountain NV, 89820
2. LOCATION SE 1/4 SE 1/4 Sec. 29 T 26 N/S R. 43 E Lander County
PERMIT NO. 55033 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay & Gravel		0	55	
Sand & Gravel		55	85	
Gravel		85	95	
Clay & Gravel		95	110	
Large Gravel & Clay		110	160	
Sandy Clay & Gravel		160	170	
Gravel		170	185	
Large Gravel		185	205	
Sand & Gravel		205	215	
Gravel		215	235	
Brown Clay		235	245	
Cobbles & Gravel		245	265	
Granite		265	273	

N40.087165
W 117.159450 NAD27

8. WELL CONSTRUCTION
Depth Drilled 273 Feet Depth Cased 273 Feet

HOLE DIAMETER (BIT SIZE)
From 0 To 273
28 Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16		.250	+1	273

Perforations:
Type perforation Sgs. Cat. double perf
Size perforation 18" X 3"
From 160 feet to 273 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 53 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From 273 feet to 53 feet

9. WATER LEVEL
Static water level 165 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name American Drilling Contractor
Address 3040 Callahan Street Contractor
Winnemucca NV 89445
Nevada contractor's license number 0020578
issued by the State Contractor's Board
Nevada driller's license number issued by the 1161
Division of Water Resources, the on-site driller
Signed _____
By driller performing actual drilling on site or contractor
Date 9-28-02

Date started 6-30 #02
Date completed 7-5 #02

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

RECEIVED
02 JUL 30 AM 10:35
DIVISION OF WATER RESOURCES OFFICE