WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 90130
Permit No.
Basin 092-A

NOTICE OF INTENT NO. 39892

1. OWNER GLENN & LISA COUCH
MAILING ADDRESS 10222 WHITE OWL RENO, NV. 89506
ADDRESS AT WELL LOCATION 10222 WHITE OWL RENO, NV. 89506

2. LOCATION NE ¼ SE ¼ Sec. 13 T. 21 N/S R. 18 E WASHOE County
PERMIT NO. N/A Issued by Water Resources
Parcel No. 086-250-43
Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☑ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☑ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN SAND CLAY AND GRAVEL LAYERS		0	290	
STARTED DEEPING WELL AT 145' AND 6" CASING BEGAN MOVING PULLED OLD CASING OUT AND REAMED HOLE W/ 9 7/8 BIT INSTALLED NEW PVC CASING TOP TO BOTTOM				

Date started 4-7-03, 19
Date completed 4-14-03, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Approx	30	280	4

8. WELL CONSTRUCTION
Depth Drilled 290 Feet Depth Cased 290 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0 Feet	10 Feet
9 7/8 Inches		10 Feet	290 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16	.188	+1	9
6 5/8	5	.990	+1	290 PVC

Perforations:
Type perforation MILL SLOT
Size perforation .030
From 150 feet to 290 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 68'
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 68 feet to 290 feet

9. WATER LEVEL
Static water level 140 feet below land surface
Artesian flow NONE G.P.M. NONE P.S.I.
Water temperature COOL °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name M&S Contractor
Address P.O Box 8056 Contractor
RENO NV 89507
Nevada contractor's license number issued by the State Contractor's Board 37915
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 148
Signed Bruce Miller
By driller performing actual drilling on site or contractor
Date 5-11-03

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627