

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25266

1. OWNER Las Vegas Valley Water Dist. ADDRESS AT WELL LOCATION Echo Rd + Kyle Canyon Rd.
 MAILING ADDRESS 1001 S Valley Blvd. Las Vegas, NV 89153
 2. LOCATION SW 1/4 NE 1/4 Sec. 26 25 T 19 N 36 E Clark County
 PERMIT NO. 69637 T SW Parcel No. 12926801002 Subdivision Name Kyle Canyon Eche View

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|--|--------------|------|-----|------------|
| Alluvium Gravels cobbles Boulders silt & sands Primarily Limestone Dolomite | 95' | 0 | 222 | 222 |
| Limestone & Dolomite with Fractures | 135-720 | 222 | 522 | |
| See Lithos. | | | | |

8. WELL CONSTRUCTION
 Depth Drilled 502 Feet Depth Cased 458 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
 36 Inches 0 Feet 90 Feet
 18 Inches 90 Feet 470 Feet
 12 Inches 470 Feet 502 Feet
 CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 24 | | 3/8" | 90 | +6" |
| 12 1/4 | | 1/4" | 458 | +2' |

 Perforations:
 Type perforation Lowered
 Size perforation 1080
 From 476 feet to 398 feet
 From 358 feet to 148 feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 90' Neat Cement
 Cement Grout
 Concrete Grout
 Placement Method: Pumped
 Poured
 Gravel Packed: Yes No
 From 470 feet to 0 feet

Date started 6-23 2003
 Date completed 8-8 2003

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---------|-------------------------------|--------------|
| 200-250 | 243 | 85 Hrs. |

9. WATER LEVEL
 Static water level 135 feet below land surface
 Artesian flow G.P.M. P.S.I.
 Water temperature 46 °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Beylik Drilling Inc. Contractor
 Address 555 S. Harbor Blvd. Contractor
 La Habra CA, 90631
 Nevada contractor's license number issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2145
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date 8-8-03

RECEIVED
 AUGUST - 8 AM 11:14
 STATE ENGINEERS OFFICE

