

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25108

1. OWNER Shelly Hickman ADDRESS AT WELL LOCATION
 MAILING ADDRESS 5185 N. Dapple Gray SE Corner Eula & Hammer
Las Vegas Nev. 89149 Las Vegas Nev.
 2. LOCATION SW 1/4 NW 1/4 Sec 31 T 19S N/S R 60 E Clark County
 PERMIT NO. 125-31-201-001 Parcel No. Subdivision Name
 Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel		0	15	
Cemented Gravel		15	70	
Clay & Gravel		70	490	
Gravel & Little water	xx	490	500	
Cemented Gravel		500	560	
Gravel & Water	xxx	560	590	
Cemented Gravel		590	610	
Gravel & Water	xxx	610	640	
Cemented Gravel		640	670	
Gravel & Water	xx	670	690	
Cemented Gravel		690	740	
Gravel and Water	xx	740	770	

RECEIVED
 SEP 05 2003
 LAS VEGAS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 770 Feet Depth Cased 770 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
12 1/4 Inches 0 Feet 50 Feet
9 7/8 Inches 50 Feet 770 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	+2	50
6 1/2	SDR	PVC	+1	770

Perforations:
 Type perforation Factory
 Size perforation .032 Sieve Type
 From 730 feet to 770 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 470 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality _____

Date started 8/18/03, 19_____
 Date completed 8/25/03, 19_____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Vernon H. Dimick
 Address 5360 N. Bonita Vista
Las Vegas, Nev. 89149
 Nevada contractor's license number issued by the State Contractor's Board 10062
 Nevada driller's license number issued by the Division of Water Resources, the onsite driller 552
 Signed V H Dimick
 By driller performing actual drilling on site or contractor
 Date 08-25-03