

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 90210
 Permit No. _____
 Basin 162

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24983

1. OWNER Shelley Cunningham ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 110 E. Falcon 110 E. Falcon
Pahrump, NV 89060

2. LOCATION SW 1/4 SW 1/4 Sec. 34 T 20S N/S R 53E E Nye County
 PERMIT NO. 40-701-20 Calvada Valley
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED 4. PROPOSED USE 5. WELL TYPE

New Well Replace Recondition Domestic Irrigation Test Cable Rotary RVC
 Deepen Abandon Other _____ Municipal/Industrial Monitor Stock Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>brown silty loam</u>		<u>0</u>	<u>14</u>	<u>14</u>
<u>brown loam</u>		<u>14</u>	<u>23</u>	<u>9</u>
<u>brown caleche</u>		<u>23</u>	<u>26</u>	<u>3</u>
<u>See next line</u>		<u>26</u>	<u>27</u>	<u>1</u>
<u>brown loam with caleche strings</u>				
<u>green silty loam</u>		<u>27</u>	<u>53</u>	<u>26</u>
<u>grey clay</u>	<u>x</u>	<u>53</u>	<u>103</u>	<u>50</u>
<u>See next line</u>	<u>x</u>	<u>103</u>	<u>145</u>	<u>42</u>
<u>brey clay with caleche strings</u>				
<u>See next line</u>	<u>x</u>	<u>145</u>	<u>152</u>	<u>7</u>
<u>brown loam with caleche strings</u>				
<u>See next line</u>	<u>x</u>	<u>152</u>	<u>160</u>	<u>8</u>
<u>rown clay with caleche strings</u>				

8. WELL CONSTRUCTION

Depth Drilled 160 Feet Depth Cased 160+1 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To
<u>11</u>	<u>0</u>	<u>160</u>
_____	_____	_____
_____	_____	_____

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>3.7</u>	<u>.280</u>	<u>0</u>	<u>160</u>
_____	_____	_____	_____	_____

Perforations:
 Type perforation sawcut
 Size perforation .188

From 140 feet to 160 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 160 feet

DNV/DWR
 RECEIVED

SEP 14 2003

LAS VEGAS OFFICE

Date started 7/24/03, 19____
 Date completed 7/24/03, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL

Static water level 72 feet below land surface
 Artesian flow _____ G.P.M. P.S.I.
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc. Contractor
 Address 5801 S. Homestead Contractor
Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board 40277
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086

Signed [Signature]
 By driller performing actual drilling on-site or contractor
 Date 8.22.03