

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23809

1. OWNER TOM SIMS ADDRESS AT WELL LOCATION 1931 W JENNIFER ST CARROLL ST PAHRUMP  
 MAILING ADDRESS 3770 E JENNIFER ST PAHRUMP NV  
 2. LOCATION NW 1/4 NW 1/4 Sec. 8 T. 19 S N/S R. 53 E Nye County  
 PERMIT NO. 27-251-49 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND - ROCKS		0	10	
SAND - Boulders		11	25	
HARD ALLUVIUM		26	155	
GRAVEL		156	160	
HARD ALLUVIUM		161	215	
GRAVEL		216	220	
HARD		220	235	
WATER	156			
WATER	216			

WATER 156  
 WATER 216  
 DONR/DWR RECEIVED  
 AUG 27 2003  
 LAS VEGAS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 235 Feet Depth Cased 235 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 0 Feet 235 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	PVC	SC40	0	220

Perforations:  
 Type perforation 5/10T  
 Size perforation 0.32  
 From 235 feet to 180 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Poured  Cement Grout  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 0 feet to 235 feet

9. WATER LEVEL  
 Static water level 136 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality Good

Date started JULY 9 15  
 Date completed JULY 21

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name GATZKE DRILLING Contractor  
 Address PO Box 6672 PAHRUMP NV 890 91 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 36415  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1650  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 6-15-03