WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 90230
Permit No.
Basin 230

NOTICE OF INTENT NO. 24959

1. OWNER Richard Bird
MAILING ADDRESS 882 S. Charity
Amargosa Valley, Nv. 89020

ADDRESS AT WELL LOCATION 882 S. Charity
Amargosa Valley, Nv. 89020

2. LOCATION SW ¼ NE ¼ Sec. 35 T. 16 N/S R. 49 E NYE County
PERMIT NO. Issued by Water Resources | Parcel No. 19-631-23 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
gravel + sand		0	50	50
Kaleachy		50	55	5
tan clay		55	75	20
limestone		75	80	5
tan clay		80	95	15
limestone		95	105	10
sand		105	120	15
limestone		120	125	5
gravel	1st	125	140	15
gravel + sand		140	170	30
white clay w/gravel layers		170	200	30
Bottom of Well			200	

DCNR/DWR
RECEIVED
AUG 27 2003
LAS VEGAS OFFICE

Date started 5/21/03 19
Date completed 5/29/03 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0 Feet	200 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	PVC		0	200
Surface Protective Casing!				
8	Steel	.188	0	7

Perforations:
Type perforation Machined
Size perforation 1/8" x 3" every 12", 4 row
From 120 feet to 160 feet
From 180 feet to 190 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 108 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Cook Drilling Co. (Contractor)
Address HCR 70 Box 543 (Contractor)
Amargosa Valley, Nv. 89020
Nevada contractor's license number issued by the State Contractor's Board 5376-A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2160
Signed (By driller performing actual drilling on site or contractor)
Date 6/13/03

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627