



App No. 90254
 Permit No. _____
 Basin 100

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 47041

1. OWNER JOE LODATO ADDRESS AT WELL LOCATION Hwy 395 + St. Rte. 208
 MAILING ADDRESS 839 Sheridan Lane Garnerville NV 89410 APN 1022-17-002-007 1541 Olympus Drive
 2. LOCATION SW 1/4 SW 1/4 Sec. 17 T. 10 N. S. R. 22 E Douglas County
 PERMIT NO. 43113/10740 37-520-12 Subdivision Name _____
Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>SOILS + CLAY</u>		<u>0</u>	<u>5</u>	<u>5</u>
<u>SOIL SAND GRAVEL 100% + some clay</u>		<u>5</u>	<u>150</u>	<u>145</u>
<u>BROKEN ROCK</u>	<u>X</u>	<u>150</u>	<u>330</u>	<u>180</u>
<u>DECOMPOSED ROCK w/ gravel</u>	<u>X</u>	<u>330</u>	<u>400</u>	<u>70</u>
<u>N39.725106</u>				
<u>W 119.547114 NAD27</u>				

8. WELL CONSTRUCTION
 Depth Drilled 400 Feet Depth Cased 400 Feet
 HOLE DIAMETER (BIT SIZE)
 From 17 1/2 Inches To 400 Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>10.75</u>	<u>-</u>	<u>.25</u>	<u>+2</u>	<u>120</u>
<u>10.75</u>		<u>.25</u>	<u>160</u>	<u>180</u>
<u>10.75</u>		<u>.25</u>	<u>200</u>	<u>220</u>
<u>10.75</u>		<u>.25</u>	<u>240</u>	<u>260</u>

Perforations:
 Type perforation _____
 Size perforation _____
 From 120 feet to 180 feet
 From 180 feet to 200 feet
 From 200 feet to 240 feet
 From 260 feet to 280 feet
 From 300 feet to 400 feet

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 100 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 100 feet to 400 feet

9. WATER LEVEL
 Static water level 57' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 3.1.02, 19____
 Date completed 4.24.02, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR LIFT</u>	<u>250-300 +-</u>		<u>8</u>
<u>PUMP</u>	<u>250</u>	<u>249'</u>	<u>10</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Sierra Nevada Drilling + Pump LLC Contractor
 Address 3540 Green Acres Dr Contractor
Carson City NV 89705
 Nevada contractor's license number 52078
 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1902
 Signed JoAnne Reich
 Driller performing actual drilling on site or contractor
 Date 5-12-02