WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 90280
Permit No.
Basin Ø44

NOTICE OF INTENT NO. 45460

OWNER KELLY BRANSTROM
MAILING ADDRESS P.O. BOX 6044
ELKO, NV 89802

ADDRESS AT WELL LOCATION GOLDRUSH AND ARAPHOE,
LOT 4, BLOCK 33

2. LOCATION SW 1/4 NE 1/4 Sec. 1 T 35N N/S R 56E E ELKO County

PERMIT NO. (Issued by Water Resources) | 030033004 Parcel No. | MVR #1 Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	6	6
SAND		6	12	6
GRAVEL		12	14	2
BROWN CLAY		14	185	171
SAND & GRAVEL	X	185	220	35

RECEIVED 02 MAY 13 PM 2:46 STATE ENGINEER'S OFFICE

Date started 4/24/2002, 19__
Date completed 4/26/2002, 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
APPROX	50		3.5

8. WELL CONSTRUCTION

Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	220 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	188	+5	220

Perforations:
Type perforation MILL SLOT
Size perforation 3/16 X 3
From 200 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 51
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout
Gravel Packed: [X] Yes [ ] No
From 51 feet to 220 feet

9. WATER LEVEL

Static water level 51 feet below land surface
Artesian flow FLOWING .75 3/4 G.P.M. .5 P.S.I.
Water temperature COLD °F Quality

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name SHAREL C. FERTIG SR., DBA FERTIG DRILLING CO. (Contractor)
Address P.O. BOX 525 (Contractor)
ELKO, NEVADA 89803
Nevada contractor's license number issued by the State Contractor's Board 0031904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed [signature] (By driller performing actual drilling, on-site or contractor)
Date 5/7/09

USE ADDITIONAL SHEETS IF NECESSARY