

COPIES TO
 - DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 90289
 Permit No. 103
 Basin 103
 NOTICE OF INTENT NO. 42032

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OWNER **SCOTT SNELLING CONSTRUCTION**
 MAILING ADDRESS **547 RAW PEAK DRIVE**
DAYTON, NV 89403

ADDRESS AT WELL LOCATION **320 COMSTOCK DR**
DAYTON, NV 89403

2. LOCATION SE 1/4 SE 1/4 Sec 9 T 16 N R 22 E LYON County
 PERMIT NO. 16-293-01

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other **MUD**

6. LITHOLOGIC LOG

Material	Water Static	From	To	Thickness
BLOW SANDS		0	3	3
HARDPAN SANDS		3	6	3
BLOW SANDS		6	21	15
COURSE SANDS DG		21	87	66
BROWN CLAY		87	146	59
GRAY CLAY		146	167	21
FRACTURED SANDS	XXX	167	200	33

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet
 HOLE DIAMETER (BIT SIZE)
 From 11 Inches To 0 Feet 200 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>200</u>

Factory Mill Slot
 Type perforation _____
 Size perforation 3 X 3/32
 From 180 feet to 200 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: _____
 Depth of Seal 55 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 55 feet to 200 feet

9. WATER LEVEL
 Static water level _____ 80 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **CAPITAL CITY WELL DRILLING**
 (CONTRACTOR)

Address **20 KIT KAT DRIVE**
 (CONTRACTOR)
CARSON CITY, NV 88706
 Nevada contractor's license number issued by the State Contractor's Board 41775

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157 11965
 Signed Michael Hest / Rick Lane
 By driller performing actual drilling on site or contractor
 Date 5/26/02

Date started 5/24, 20 02
 Date completed 5/25, 20 02

7. WELL TEST DATE

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25+</u>	<u>25</u>	<u>3 HRS</u>

RECEIVED
 02 MAY 31 AM 8:26
 STATE ENGINEERS OFFICE