

Log No. 90300
 Permit No. _____
 Basin 099

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 4793

1. OWNER J & L Builders ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 10900 Red Rock Rd 16105 Roundup Rd Reno NV
Reno NV 89506 89506
 2. LOCATION SW 1/4 SW 1/4 Sec. 35 T. 24 S. R. 18 E Washoe County
 PERMIT NO. 078-241-01 Subdivision Name Rancho Sierra
 Issued by Water Resources Parcel No. _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	15	15
Sand		15	35	20
Clay		35	63	28
Sand		63	75	12
Sand (Fine)		75	155	80
Clay & Sand layers		155	165	10
Sand (Coarse)		165	197	32

8. WELL CONSTRUCTION
 Depth Drilled 197 Feet Depth Cased 197 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
11 Inches 0 Feet 197 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.9</u>	<u>3/16</u>	<u>2+</u>	<u>197</u>

Perforations:
 Type perforation Saw Slot
 Size perforation 3/16
 From 197 feet to 157 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 197 feet

9. WATER LEVEL
 Static water level _____ feet below land surface
 Artesian flow Yes G.P.M. .05 P.S.I.
 Water temperature NA °F Quality NA

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Oleksi Drilling & Pump Co.
 Address 15045 Red Rock Rd
Reno NV 89506
 Nevada contractor's license number issued by the State Contractor's Board 50343
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1656
 Signed John F. Oleksi
 By driller performing actual drilling on site or contractor
 Date 4/27/03

Date started 4/15, 2003
 Date completed 4/25, 2003

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20</u>	<u>140</u>	<u>4</u>