

Log No. 90316  
 Permit No. \_\_\_\_\_  
 Basin. 101

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 51243

1. OWNER TIM COVERTSON ADDRESS AT WELL LOCATION 980 BENOIT RD  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION SW 1/4 SW 1/4 Sec. 7 T 19 N R 27 E Churchill County  
 PERMIT NO. 007-111-19 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Municipal/Industrial  Irrigation  Monitor  Test  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		0	15	15
SAND		15	60	45
BLACK CLAY		60	95	35
CLAY		95	100	5
SAND		100	129	29

8. WELL CONSTRUCTION  
 Depth Drilled 129 Feet Depth Cased 129 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 Inches To 0 Feet 129 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>32</u>	<u>.280</u>	<u>0</u>	<u>129</u>

Perforations:  
 Type perforation SLOTS  
 Size perforation 3 x 1/8  
 From 124 feet to 129 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  
 Depth of Seal 52'  Cement Grout  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No  
 From 52' feet to 129' feet

Date started 12-19, 2002  
 Date completed 12-22, 2002

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>15</u>	<u>20</u>	<u>4</u>

9. WATER LEVEL  
 Static water level 70 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 62.0 °F Quality UNKNOWN

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name FARRIS DRILLING Contractor  
 Address PO Box 5205 Contractor  
FALLON NV 89407  
 Nevada contractor's license number issued by the State Contractor's Board 43145  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2082  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 1-18-03