WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

I

OFFICE USE ONLY
Log No. 90329
Permit No.
Basin 107

NOTICE OF INTENT NO. 47917

1. OWNER William Weaver
MAILING ADDRESS William Weaver
Lazy W. Ranch Wellington Nev.
ADDRESS AT WELL LOCATION Wellington Nev.

2. LOCATION ~~SW~~ ¼ ~~SE~~ ¼ Sec. 17 ~~13~~ T. 10 N/S R. ~~16~~ ~~25~~ 24 E. Lyon County
PERMIT NO. NW NW 10-741-31
Issued by Water Resources — Parcel No. — Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☑ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☑ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| brown clay | | 215 | 232 | 17 |
| gravel + sand | yes | 232 | 278 | 46 |
| brown sandy clay | | 278 | 305 | 27 |
| rock + gravel | ✓ | 305 | 327 | 22 |
| sand clay | | 327 | 330 | 3 |
| strata of Rock between | ✓ | | | |
| clay layers | | 330 | 360 | 30 |

RECEIVED
03 AUG 21 AM 10:41
STATE ENGINEERS OFFICE

Date started June 8 - 03, 19
Date completed June 20 - 03, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☑ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 30 | 5 | 12 |

8. WELL CONSTRUCTION
Depth Drilled 360 Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)
6 5/8 Inches From 215 Feet To 360 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | | 188 | 0 | 360 |

Perforations:
Type perforation Factory Saw Slott
Size perforation 3/32 x 3
From 260 feet to 300 feet
From 320 feet to 360 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☑ No
Depth of Seal already sealed
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From — feet to feet

9. WATER LEVEL
Static water level 190 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Edmund Miller Drilling
Contractor
Address PO. Box 92
Contractor
Smith Nev. 89430
Nevada contractor's license number issued by the State Contractor's Board 32166 A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718
Signed Edmund Miller
By driller performing actual drilling on site or contractor
Date May 20 - 03

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627