WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 90331
Permit No.
Basin 107

NOTICE OF INTENT NO. 47922

1. OWNER JOSE A POMALES
MAILING ADDRESS 1110 E 5TH AVE MOUNT DORA FLORIDA 32757
ADDRESS AT WELL LOCATION 33 TERREL WELLINGTON, NV. 89444

2. LOCATION NW ¼ SE ¼ Sec. 33 T. 12 N/S R. 23 E. LYON County
PERMIT NO. (Issued by Water Resources) 09-033-05 (Parcel No.) PINE NUT RANCH ESTATES (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[X] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SURFACE ROCK/TOPSOIL	—	0	12	12
SANDY BROWN CLAY/ROCKS	—	12	195	183
HEAVY SAND/GRAVEL	YES	195	250	55

RECEIVED 03 AUG 21 AM 10:41 STATE ENGINEERS OFFICE

Date started AUG 8, 03, 19
Date completed AUG 20 03, 19

7. WELL TEST DATA
TEST METHOD: [X] Bailer [X] Pump [ ] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
BAIL	18 +/-	15	6
PUMP	18	15	4

8. WELL CONSTRUCTION
Depth Drilled 250 Feet Depth Cased 250 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches		0 Feet	60 Feet
6 5/8 Inches		60 Feet	250 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	12.92	.188	+1.5	250

Perforations:
Type perforation FACTORY SAW SLOT
Size perforation .060 X 2 X 6 OC - 6 ROWS
From 210 feet to 250 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 55'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 175 feet below land surface
Artesian flow NO G.P.M. P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EDMUND MILLER DRILLING (Contractor)
Address PO BOX 92 SMITH NV 89430 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 32166 A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718
Signed Edmund Miller (By driller performing actual drilling on site or contractor)
Date Aug 20 - 03

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627