WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 90333
Permit No.
Basin 087

NOTICE OF INTENT NO. 46067

1. OWNER Regional Transportation Commission
MAILING ADDRESS 1105 Terminal Way Suite 108 Reno, NV 89502
ADDRESS AT WELL LOCATION E. 4th St. & UPRR track between Lake St. & Evans Ave 205 E. Plaza

2. LOCATION SE ¼ NE ¼ Sec. 11 T. 19 N/S R. 19 E. WASHOE County
PERMIT NO. M/O-1281 (Issued by Water Resources) 07-311-01, 04, 05, 06, 09 & 011-380-05 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
gravel + cobbles		0	15	
gravel, some fines		15	27	
gravels, water, less fines	27'	27	~~31~~ 38	
Plugged under NOI 62807				
N 39.529839				
W 119.810045 NAD27				

RECEIVED 03 AUG 18 PM 1:12 STATE ENGINEER'S OFFICE

Date started Aug 4 03, 19
Date completed Aug 4 03, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 38 Feet Depth Cased 38 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 Inches		0 Feet	38 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	sch 40	PVC	0	23

Perforations:
Type perforation factory slotted
Size perforation .020
From 38 feet to 23 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 19'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 38 feet to 21 feet

9. WATER LEVEL
Static water level 22' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Brent Longyear (Contractor)
Address Box 1000 (Contractor)
Dayton, NV 89403
Nevada contractor's license number issued by the State Contractor's Board 0010157
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2198
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 8/13/03

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627