

n.w. 5

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT



OFFICE USE ONLY

Log No. 90344
Permit No. _____
Basin 087

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 46067

1. OWNER Regional Trans. Commission ADDRESS AT WELL LOCATION East near 4th Street and the U.P. Railroad Tracks between Lake St. and Evans Ave., Reno, NV. 89502
MAILING ADDRESS 1105 Terminal Way, Suite 108 Reno, NV. 89502
2. LOCATION SE 1/4 NE 1/4 Sec. 11 T. 19 N. S. R. 19 E Washoe County
PERMIT NO. mpo-1281 Parcel No. 07-311-06 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Concrete		0'	1'	1'
Backfill-Gravel		1'	4'	3'
Small Cobbles		4'	18'	14'
Gravels & Cobbles-Gray		18'	26'	8'
Sandy Gravel-Moist		26'	34'	8'
Gravels & Cobbles-Gray, Wet		34'	43'	9'
Plugged under NDC 62803				
N39.530009				
WELL 280425 NAD27				

8. WELL CONSTRUCTION
Depth Drilled 43' Feet Depth Cased 43' Feet
HOLE DIAMETER (BIT SIZE)
From To
6" Inches 0' Feet 43' Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>	<u>Sch. 40</u>	<u>P.V.C.</u>	<u>0'</u>	<u>28'</u>

Perforations:
Type perforation Factory Cut
Size perforation 0.020
From 28' feet to 43' feet
From _____ feet to _____ feet
Surface Seal: Yes No Seal Type:
Depth of Seal 24' Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 27' feet to 43' feet

9. WATER LEVEL
Static water level 28' feet below land surface
Artesian flow no G.P.M. _____ P.S.I. _____
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Boart Longyear Phillip Cramer Contractor
Address P.O. Box 1000 Dayton, NV. 89403 Contractor
Nevada contractor's license number issued by the State Contractor's Board 0010157
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2148
Signed Phillip C. Cramer
By driller performing actual drilling on site or contractor
Date 8-15-03

Date started 8-13- 2003
Date completed 8-13- 2003

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
03 AUG 18 PM 1:12
STATE ENGINEERS OFFICE