WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 90345
Permit No.
Basin 087

NOTICE OF INTENT NO. 46067

1. OWNER Regional Trans Comm
MAILING ADDRESS 1105 Terminal Way Suite 108 Reno, NV 89502
ADDRESS AT WELL LOCATION E. 4th St + UPRR tracks between Lake St. + Evans Ave Reno

2. LOCATION SE ¼ NE ¼ Sec. 11 T. 19 N/S R. 19 E. WASHOE County
PERMIT NO. M/O-1281 Issued by Water Resources
07-311-09 Parcel No.
Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
cobbles		0	20	
gravel/cobbles		20	28	
gravel		28	41	

RECEIVED
03 AUG 18 PM 1:12
STATE ENGINEER'S OFFICE

Date started 8/12/03, 19
Date completed 8/12/03, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 41 Feet Depth Cased 41 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6" Inches	0 Feet	41 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	sch. 40	PVC	0	26

Perforations:
Type perforation Factory slotted
Size perforation .020
From 26 feet to 41 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 22
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 41 feet to 24 feet

9. WATER LEVEL
Static water level 22 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Bart Construction Contractor
Address Box 1000 Contractor
Dayton, NV 89403
Nevada contractor's license number issued by the State Contractor's Board 0010157
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2198
Signed [signature] By driller performing actual drilling on site or contractor
Date 8/13/03

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627