mw-7

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 90350
Permit No.
Basin 087

NOTICE OF INTENT NO. 46067

1. OWNER Regional Transportation Commission
MAILING ADDRESS 1105 Terminal Way, Suite 108 Reno, Nv. 89502
ADDRESS AT WELL LOCATION East 4th St. and the U.P. Railroad Tracks between Lake St. and Evans Ave. Reno, Nv. 89502

2. LOCATION SE ¼ NE ¼ Sec. 11 T. 19 N/S R. 19 E. Washoe County
PERMIT NO. M/D-1281 Issued by Water Resources
07-311-06 Parcel No.
Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
GRAVEL-Dirt-Grey		0'	4'	4'
Granite Boulder		4'	11'	7'
Cobbles-small to Medium		11'	20'	9'
Gravels-Wet		20'	39'	19'
Plugged under NDOT 62863				
N 39.530654				
W 119.809405 NAD27				

RECEIVED
03 AUG 18 PM 1:12
STATE ENGINEERS OFFICE

Date started 8-14-, 2003
Date completed 8-14-, 2003

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 39' Feet Depth Cased 39' Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
6"	0'	39'

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	sch. 40	P.V.C.	0'	24'

Perforations:
Type perforation Factory Cut
Size perforation 0.020
From 24' feet to 39' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 20'
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 22' feet to 39' feet

9. WATER LEVEL
Static water level 22.5' feet below land surface
Artesian flow NO G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Bart Longyear Phillip Cramer
Contractor
Address P.O. Box 1000 Dayton, Nv. 89403
Contractor
Nevada contractor's license number issued by the State Contractor's Board 0010157
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2148
Signed Phillip C. Cramer
By driller performing actual drilling on site or contractor
Date 8-15-03

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627