

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT



office use only
Log No. 90355
Permit No.
Basin 087

NOTICE OF INTENT NO 49113

1. OWNER **Eric Halvorson**
MAILING ADDRESS **1825 Catalpa Ln**
Reno NV

ADDRESS AT WELL LOCATION **1825 Catalpa Ln**

2. Location **NW 1/4 SW 1/4 Sec 1 T 18N R 19E** Washoe County
PERMIT NO. PARCEL NO. **040-612-05** SUBDIVISION NAME

3. WORK PERFORMED			4. PROPOSED USE			5. WELL TYPE		
New Well	Replace	Recondition	<input checked="" type="checkbox"/> Domestic	Irrigation	Test	Cable	Rotary	RVC
Deepen	<input checked="" type="checkbox"/> Abandon	Other	Municipal/Industrial	Monitor	Stock	Air	Other	Mud

6. LITHOLOGIC LOG					8. WELL CONSTRUCTION					
Material	Water Strata	From	To	Thickness	Depth Drilled	HOLE DIAMETER (BIT SIZE)	Depth Cased	From	To	
Installed termie to 170' & pumped neat cement to surface. We did get returns.		0		0	12	inches	0	feet	170	
				0		inches		feet	feet	
				0		inches		feet	feet	
						CASING SCHEDULE				
				0	0	Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
				0	0	6 5/8	12.94	188	+1 1/2	170
				0	0					
				0	0					
				0	0					
				0	0					
					Perforations::					
			0	0	Type Perforation	Mills Knife				
			0	0	Size perforation	1/4 x 4				
			0	0	From	0	feet to	170	feet	
			0	0	From		feet to		feet	
			0	0	From		feet to		feet	
			0	0	From		feet to		feet	
			0	0	From		feet to		feet	
			0	0						
			0	0	Surface Seal	<input checked="" type="checkbox"/> YES	No		Seal Type:	
			0	0	Depth of Seal	170	feet		<input checked="" type="checkbox"/> Neat Cement	
			0	0					<input checked="" type="checkbox"/> Pumped	
			0	0					Cement Grout	
			0	0					Concrete Grout	
			0	0	Gravel Packed:	Yes	No			
			0	0	From		feet to	feet		
					9. WATER LEVEL					
			0	0	Static water level	47	feet below land surface			
			0	0	Artesian flow	0	GPM	0	P.S.I.	
			0	0	Water Temperature	cold	Degrees F		Quality	

RECEIVED
 03 AUG 25 PM 1:03
 CIVIL ENGINEERS OFFICE

Date started **7-18 -03**
Date completed **7-18 -03**

7. WELL TEST DATA			
TEST METHOD:	Bailer	Pump	<input checked="" type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)		Time (hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **McKay Drilling, Inc.**
2290 Pioneer Drive
Reno, NV 89509
 NV Contractors No. **14170**
 NV Driller's Lic (on site) **12617**
 Signed *Steve MWR*
 By driller performing actual drilling on site or contractor
 Date **7-23 -03**