WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 90358
Permit No.
Basin 107

NOTICE OF INTENT NO. 47919

1. OWNER GARY AIAZZI
MAILING ADDRESS 1407 ORCHARD RD. GARDNERVILLE, NV. 89410
ADDRESS AT WELL LOCATION 477 HWY. 338 WELLINGTON, NV. 89444

2. LOCATION SW ¼ SW ¼ Sec. 18 T. 10 N R. 24 E. LYON County
PERMIT NO. (Issued by Water Resources) 010-741-43 (Parcel No.) NONE (Subdivision Name)

3. WORK PERFORMED: [X] New Well [ ] Replace [ ] Recondition [ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE: [X] Domestic [ ] Irrigation [ ] Test [ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE: [X] Cable [ ] Rotary [ ] RVC [ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SURFACE ROCK/TOPSOIL	NO	0	6	6
CLECHE CLAY	—	6	18	
BWN. CLAY/ROCK	—	18	95	
SHARP HVY. SAND SM GRAVEL		95	110	
BWN. CLAY/SHARP	—			
HEAVY SAND W/	—			
LAYERS OF ROCK	—	110	195	
BIG BOULDER	—	195	199	
HARD ROCK LT. BWN CLAY	—	199	230	
SANDY BWN CLAY	NO	230	260	
LARGE SHARP SAND	YES			
W/CLAY STRIPS	YES	260	280	
LARGE SHARP SAND	YES			
+ SMALL GRAVEL	YES	280	340	
HARD DRY	YES			
BWN. CLAY	NO	340		

RECEIVED 03 AUG 21 AM 10:41 STATE ENGINEERS OFFICE

Date started JULY 05 03, 19
Date completed JULY 19 03, 19

7. WELL TEST DATA

TEST METHOD: [X] Bailer [X] Pump [ ] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
BAIL	16	5	6
PUMP	30	65	6
	4.8 GPM RECOVERY RATE		

8. WELL CONSTRUCTION
Depth Drilled 340 Feet Depth Cased 340 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches		0 Feet	60 Feet
6 5/8 Inches		60 Feet	340 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625		.188	+2	340

Perforations:
Type perforation FACTORY SAW SLOT
Size perforation .060 X 6" OL - 6 ROWS
From 310 feet to 340 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 55
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] ~~Cement Grout~~ [X] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 230 feet below land surface
Artesian flow NO G.P.M. — P.S.I.
Water temperature 48 °F Quality EXELENT

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EDMUND MILLER DRILLING CO. (Contractor)
Address PO. BOX 92 SMITH, NV. 89423 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 32166-A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2232
Signed BILL SUTTON (By driller performing actual drilling on site or contractor)
Date JULY 19 03

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627