

Log No. 90362
Permit No. _____
Basin. 887

m.w.PR-1
PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 46061

1. OWNER Washoe County Dept of Water Resources ADDRESS AT WELL LOCATION 55 South 15th Ave Sparks, NV
MAILING ADDRESS 4930 Energy Way Reno, NV 89502
2. LOCATION SE 1/4 NW 1/4 Sec. 8 T. 19 N. R. 20 E. Washoe County
PERMIT NO. 32-27-513 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Rotary - Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Gravel, Silty, Sand Brown	Dry	0	11	11
Gravel, Sand, Silty Gray	moist	11	24	13
Gravel, Clay, Silt	Wet	24	36	12
Gravel, Clay, Sand, Brown	Wet	36	43	7

8. WELL CONSTRUCTION
Depth Drilled 43 Feet Depth Cased 43 Feet

HOLE DIAMETER (BIT SIZE)
From 6 Inches 0 Feet 43 Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	Sch 40		0	20

Perforations:
Type perforation Factory Cut
Size perforation .020
From 20 feet to 40 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 15 ft Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From 18 feet to 43 feet

9. WATER LEVEL
Static water level _____ feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

Date started 8.4, 2003
Date completed 8.5, 2003

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name BOART LANGRISH Contractor
Address 32 Stokes Dr Po Box 1000 Dayton, NV 89403 Contractor
Nevada contractor's license number issued by the State Contractor's Board 0010157
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-24BT2
Signed Si Bugg
By driller performing actual drilling on site or contractor
Date 8-15-03

RECEIVED
03 AUG 20 AM 10:57
STATE ENGINEERS OFFICE